

CERTIFICATE of Conformity



Registration No.: AK 50531708 0001

Report No.: JP22K68I 001

Holder: **NIHONKOSO CO., LTD**
KOSO ENGINEERING DIVISION
1-16-7 Nihombashi,
Chuo-ku, Tokyo
103-0027 Japan

Product: Valve Controller
Smart Valve Positioner

Identification: Type Designation: KGP2000 series
Serial Number: Engineering sample
Degree of Protection: IP66

Remark: Design acc. to report JP22K68I 001, Attachment A.

Tested acc. to: EN 60529:1991+A1+A2
IEC 60529 Ed. 2.2:2013

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Yokohama, 27.01.2022


Dipl.-Ing. (FH) M. Geiser

TÜV Rheinland Japan Ltd. - Yokohama 222-0033 - JAPAN

